




LEGENDA

- 1 - Unitate de debit contor Dn20 tip MTHI ZENNER T=130°C, PN 16bar
 - 2 - Robinet izolare Dn40mm T=130°C, PN 25bar
 - 3 - Robinet izolare Dn40mm T=130°C, PN 16bar
 - 4 - Robinet limitator de debit Q_{max}=1,12mc/h, T=130°C, PN16bar
 - 5 - Tronson conducta Ø48x3mm,
 - 6 - Calculator
 - 7 - Sonda de temperatura
 - 8 - Tronson conducta Ø28x3mm
 - 9 - Flanse pt montat diafragama
- Cablul conectare contor

SC GLOBAL SERV SRL

BENEFICIAR: SC Administratia Domeniului Public SA
DOCUMENTATIE AVIZ DE RACORDARE RACORD TERMIC PRIMAR
CLADIRE PARKING SUBTERAN
STR. INDEPENDENTEI

3618/
2015

SEF PROIECT	ING. IUONAS SORIN	
PROIECTAT	ING. IUONAS SORIN	
VERIFICAT	ING. IUONAS DOINA	

IULIE
2015

**MONTAJ CONTOR
ENERGIE TERMICA**

1M